



Certificate of Compliance

Certificate: 70176031

Master Contract: 266494

Project: 70199399

Date Issued: 2018-10-10

Issued to: **LONGI Green Energy Technology Co., Ltd**
No. 388, Middle Hangtian Road
Chang'an District, Xi'an, Shaanxi 710100
China
Attention: Fei Zhuang

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: *Tao (Tom) Yang*
Tao (Tom) Yang

PRODUCTS

CLASS – C531110 – POWER SUPPLIES-Photovoltaic Modules and Panels

CLASS – C531190 – POWER SUPPLIES-Photovoltaic Modules and Panels – Certified to US Standards

Bifacial or dual glass crystalline silicon photovoltaic modules with maximum system voltage up to 1500 V dc, New Type module fire performance, similar to Type 3, Class C fire resistance rating (for Canada). Models as below:

LR6-72BP-xxxM, xxx=350 to 370, in steps of 5W,

LR6-72PD-xxxM, xxx= 345 to 370, in steps of 5W,

LR6-72DG-xxxM, xxx= 330 to 360, in steps of 5W,

LR6-60BP-xxxM, xxx=290 to 310, in steps of 5W,

LR6-60PD-xxxM, xxx=285 to 305, in steps of 5W,

LR6-60DG-xxxM, xxx=275 to 300, in steps of 5W, with the electrical ratings as specified below at Standard Test Conditions.

Notes:

1. Rated electrical characteristics are within +/- 5% of measured values at Standard Test Conditions of 100 mW/cm² irradiance, AM 1.5 spectrums, and 25°C.
2. Rated electrical characteristics are only reflected the front side performance, regardless of the back side.
3. All modules model with suffix 'BP' after '72' or '60', are bifacial modules
4. All modules model with suffix 'PD' after '72' or '60', are modules with PERC cells.



Certificate: 70176031

Project: 70199399

Master Contract: 266494

Date Issued: 2018-10-10

5. All modules model with suffix 'DG' after '72' or '60', are modules with common one side mono-si cells.

APPLICABLE REQUIREMENTS

ULC/ORD – C1703-01	-	Flat-Plate Photovoltaic Modules and Panels
UL 1703-3 rd Ed	-	Flat-Plate Photovoltaic Modules and Panels



Supplement to Certificate of Compliance

Certificate: 70176031

Master Contract: 266494

Product Certification History

Project	Date	Description
70199399	2018-10-10	Update report 70176031 to add alternate frame design for height of 30mm and 25mm to 72 Pcs module. Encapsulation Cybright T22 and 8110, alternate superstrate by China CSG Holding and SUOLATE SPECIAL GLASS (JIANGSU) CO., LTD. Add manufacturers for Interconnection/End Ribbons and frame, with the declaration by LONGI, change cell type naming by the request from LONGI.
70196050	2018-09-06	Update report 70176031 to add alternate frame design for height of 30mm and 25mm to 72 Pcs module.
70181445	2018-05-04	Update report to add new models LR6-72PD-xxxM, LR6-72DG-xxxM, LR6-60BP-xxxM, LR6-60PD-xxxM, LR6-60DG-xxxM for approved cells in report 70065662, add label approved information.
70176031	2018-03-23	CSA C/US Certification for Bifacial Photovoltaic Modules with maximum system voltage up to 1500 V dc, Model LR6-72BP-350M, LR6-72BP-355M, LR6-72BP-360M, LR6-72BP-365M.